

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 283

Dated: 16/2/2024.

It is certified that an inspection team headed by Dr. Imran Ali Khan

from CHC MAHOLI inspected the BLISS INTERNATIONAL SCHOOL

BARSOHIYA MAHOLI on 16/2/2024 and on the basis of Water Test Report no.

U1684859S13103319 dated 26/06/2023 of U.P. JAL NIGAM (RURAL), SITAPUR certified that

the BLISS INTERNATIONAL SCHOOL BARSOHIYA MAHOLI has safe drinking water facilities for

the students and members of staff of the institution. School also maintains the hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T.

Govt.

This certificate is valid till 1 year

To

BLISS INTERNATIONAL SCHOOL

BAROHIYA MAHOLI

Signature with Seal:

Medical Superintendent
CHC Maholi, Sitapur

Name

Dr. Imran Ali Khan

Designation

Superintendent

Name & Address


Of Office/ Department CHC Mahol



MANAGER

BLISS INTERNATIONAL SCHOOL

Barschiya, Maholi



PRINCIPAL

BLISS INTERNATIONAL SCHOOL

Barschiya, Maholi

District Level Water Analysis Laboratory, U.P Jal Nigam (Rural), Sitapur

Arya Nagar near water tank, Sitapur. Pin- 261001 (Test Address only)

Test report

Sample ID: U1684859S13103319

User Information

Name: BLISS INTERNATIONAL SCHOOL Mobile: 9450373600

Email: avadheshverma9450@gmail.com Pin Code:

Full Address: Village- Barsahia, Gram Panchayat- Adhaura, Block- Maholi, District- Sitapur, State- Uttar Pradesh

Sample description

Source of Sample: Tube well / Bore well / Well Village: Barsahia

Gram Panchayat: Adhaura Block: Maholi

District: Sitapur State: Uttar Pradesh

Address: Remarks: Bliss International School

Latitude: Longitude:

Date & time of sample collection	Date & time of sample received in lab	Date & time of sample analysed	Date & time of report generation
23.06.2023 03:28:00 PM	23.06.2023 03:30:00 PM	24.06.2023 10:47:00 AM	24.06.2023 10:47:00 AM

Test results

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit in absence of alternate source) as per BIS 10500	Test result value	Remarks
1	Calcium (as Ca)	mg/l	75	200	28.800	
2	Chloride (as Cl)	mg/l	250	1000	24.000	
3	Colour	Hazen units	5	15	0.000	
4	E. coli	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
5	Fluoride (as F)	mg/l	1	1.5	0.090	

PRINCIPAL

MANAGER

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit in absence of alternate source as per BIS 10500	Test result value	Remarks
6	Iron (As Fe)	mg/l	1	No Relaxation	0.000	
7	Magnesium (As Mg)	mg/l	30	100	40.800	
8	Nitrate (as NO3)	mg/l	45	No Relaxation	0.000	
9	Odour	NA	Agreeable	Agreeable	0.000	
10	pH	NA	6.5-8.5	No Relaxation	7.500	
11	Sulphate (as SO4)	mg/l	200	400	28.580	
12	Taste	NA	Agreeable	Agreeable	0.000	
13	TDS	mg/l	500	2000	342.000	
14	Total Alkalinity (as Calcium Carbonate)	mg/l	200	600	168.000	
15	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
16	Total Hardness (As CaCO3)	mg/l	200	600	240.000	
17	Turbidity	NTU	1	5	0.300	

Note:

- 1)*indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Authorised signatory
Ankit Chauhan (Test Lab Incharge)


Jal Jeevan Mission aims at potable tap water supply to every home

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by NIC. Copyright ©copy NJJM 2022

Print


MANAGER
BLISS INTERNATIONAL SCHOOL
Barsohiya, Maholi


PRINCIPAL
BLISS INTERNATIONAL SCHOOL
Barsohiya, Maholi